

Draft Decision Paper – Definition for the scope of gas works CER/09/032 19<sup>th</sup> February 2009

## Appendix A – List of Substantive Questions

It should be noted **that respondents are in no way obliged to respond to the table provided below and are welcome to submit**

**comments in their preferred format.** It is included to allow for a “short-cut” option for respondents to submit their comments to the Commission

Respondents are invited to complete the table to indicate their position on the questions being asked. Respondents should outline

YES or NO answers to each of the questions listed. If you have a further comment which will clarify your answer, this should be included in the Comments box.

### Question/ Proposal

**Q1.** Do you agree with the proposed definitions for Domestic, Commercial and Industrial Gas Customers in Section 3.2?

<b>Yes</b>	Yes
------------	-----

<b>No</b>	
-----------	--

**Comments:**

### Question/ Proposal

**Q2.** Do you agree with the Commission’s proposals set out in Section 5?

<b>Yes</b>	Yes
------------	-----

<b>No</b>	
-----------	--

**Comments**

### Additional comments from GTSC TC2

4.2.4: Specific rating, i.e. kW input needs to be specified for boilers to differentiate between domestic and commercial type boiler.

There are a number of references of up to 60kW in the Irish Building Regulations Part J. There is also a reference of up to 70kW in referenced standard EN 483. In neither document is it absolutely clear that these are set limits.