

Overall it looks fine the only problem I can see is 5.2.2 Commercial Gas Installers page 18 at the end of that section, the Commission propose that commercial Gas Works will be covered with the exception of the following:

- The welding of pipework for commercial customers; This I feel should state prior to the admission of Gas, as following the pipe work carrying gas there are a lot more to be considered and as a result the person welding this pipework should have knowledge of gas safety.
- Also the testing and purging if this gas line should be carried out by a trained person as a result of the dangers associated with Purging in particular. The contractor or installer fitting commercial should of safety reasons test and purge the pipework and admit gas to the service valves provided for the appliances to be attached.