



**Distribution Loss Adjustment Factors**  
**1<sup>ST</sup> OCTOBER 2014 – 30<sup>TH</sup> SEPTEMBER 2015**

**Issued by: Distribution System Operator  
ESB Networks**

---

### Distribution Loss Adjustment Factors

Voltage Level	Time Period		
	Composite	Day	Night
38kV Sales	1.015	1.016	1.013
MV Sales	1.035	1.038	1.030
LV Sales	1.085	1.091	1.073
Aggregate	1.070	1.074	1.060

The major time periods relate to the day and night rate units used in the two part tariffs. These time periods are applied as follows:

- For customers connected at LV with non quarter-hourly meters:

The day period covers the time from 8.00 a.m. to 11.00 p.m. in winter and 9.00 a.m. to 12.00 p.m. during summer.

- For LV customers with quarter-hourly meters, MV and 38kV customers:

Day-time is from 8.00 a.m. to 11.00 p.m., summer and winter. The night period covers the remaining hours from 11.00pm to 8.00am.

Only the day and night loss adjustment factors are used for settlement purposes.